

Approved Document F - Ventilation

This document covers means of ventilation within new dwellings, new buildings other than dwellings and existing buildings. The types of ventilation covered includes, mechanical, passive stack, background and purge (rapid).

2006 edition: Valid from 6 April 2006



The requirement in this edition of Approved Document F is as follows:

Requirement

Part F Means of ventilation

F1. There shall be adequate means of ventilation provided for people in the building.

Limits on application

Requirement F1 does not apply to a building or space within a building:

- (a) into which people do not normally go; or
- (b) which is used solely for storage; or
- (c) which is a garage used solely in connection with a single dwelling.